

## **IC 13-23-5**

### **Chapter 5. Installation of Underground Storage Tanks**

#### **IC 13-23-5-1**

##### **Restrictions on time**

Sec. 1. Subject to section 2 of this chapter, an underground storage tank, whether of single or double wall construction, may not be installed before the effective date of the rules adopted under IC 13-23-1-2 for the purpose of storing regulated substances unless:

- (1) the tank will prevent releases due to corrosion or structural failure for the operational life of the tank;
- (2) the tank is:
  - (A) cathodically protected against corrosion;
  - (B) constructed of noncorrosive material;
  - (C) steel clad with a noncorrosive material; or
  - (D) designed to prevent the release or threatened release of any stored substance; and
- (3) the material used in the construction or lining of the tank is compatible with the substance to be stored.

*As added by P.L.1-1996, SEC.13.*

#### **IC 13-23-5-2**

##### **Restrictions based on soil resistivity**

Sec. 2. If soil tests conducted in accordance with:

- (1) ASTM Standard G57-78; or
- (2) another standard approved by the commissioner as exhibiting the same or a greater degree of reliability and accuracy;

show that soil resistivity in an installation location is at least twelve thousand ohms per centimeter (12,000 ohm/cm), a storage tank without corrosion protection may be installed in that location during the period referred to in section 1 of this chapter.

*As added by P.L.1-1996, SEC.13.*